


## Product Code

# 6110/X21

Receiver Valve



### Product use

Accessories for use with the following ASHRAE 34:2019 refrigerants, Class A1:

HCFC (R22)

HFC (R134a, R404A, R407C, R410A, R507)

HFO (R1234ze)

HFO + HFC (R448A, R449A, R450A, R452A, R513A, R515A, R515B)

### Product Details

**Access fitting SAE Flare** 1/4" f (1)

**Connections SAE Flare** 1/4"

**Connections NPT** -

**Kv [m<sup>3</sup>/h]** 0,44

**PS [bar]** 45

**MWP [psi] (2)** 650

**TS [°C] min.** -40

**TS [°C] max.** +130

**Package pcs** 90

### Notes where expressly stated

(1): can be used without copper gasket

(2): according to UL approval

(3): not UL approved