
# Product Code

# 6120E/33

Receiver Valve CO2
3/8"FlareX3/8"NPT<br>PS = 140 bar - 2030 psi



## Product use

Accessories for use with refrigerant R744.

## Product Details

| | |
|---|---|
| **Connections SAE Flare** | - |
| **Connections SAE Flare** | 3/8" |
| **NPT** | 3/8" |
| **NPT** | - |
| **Kv [m³/h]** | 1,35 |
| **PS [bar]** | 140 |
| **MWP [psi] (3)** | 2030 |
| **TS [°C] min.** | -40 |
| **TS [°C] max.** | +150 |
| **Package pcs** | 90 |

## Notes where expressly stated

(1): including a conical gasket 7580/2
(2): can be installed without gasket
(3): according to UL approval

*Castel non si assume alcuna responsabilità per eventuali errori nei cataloghi, opuscoli e altro materiale stampato o indicato nel sito Castel.it. Castel si riserva il diritto di modificare i propri prodotti senza preavviso. Tutti i marchi in questo materiale sono di proprietà di Castel. Tutti i diritti riservati.*
*Castel assumes no responsibility for any errors in catalogs, brochures and other material printed or indicated on the Castel.it website. Castel reserves the right to modify its products without notice. All trademarks in this material are the property of Castel. All rights reserved.*