



Product Code

3145W/21

Check Valve

2.5/8" ODS

PS = 45 bar - (2) PSI

Product use

Accessories for use with the following ASHRAE 34:2019 refrigerants, Class A1:

HCFC (R22)

HFC (R134a, R404A, R407C, R410A, R507)

HFO (R1234ze)

HFO + HFC (R448A, R449A, R450A, R452A, R513A, R515A, R515B)

Product details

Attacchi SAE Flare -

Attacchi ODS Ø [in.] 2.5/8"

ODS Ø [mm] -

Kv [m³/h] 39

Pressione differenziale (2) [bar] 0,3

PS [bar] 45

MWP [psi] (1) 650

TS [°C] Min -40

TS [°C] Max +150

Confezione n° pz 1

Notes

(1): in conformità a omologazione UL

(2): non omologato UL

(3): minima pressione a cui la valvola è completamente aperta