

Product Code

**3112W/6**

Check Valve


3/4" Flare

PS = 50 bar - 600 PSI



### Product use

Accessories for use with the following ASHRAE 34:2019 refrigerants, Class A1, A2L, or A3:  
 HFC (R134A, R32, R404A, R407C, R410A, R507)  
 HFO (R1234YF, R1234ZE)  
 HFO + HFC (R448A, R449A, R450A, R452A, R452B, R454A, R454B, R454C, R455A, R513A, R515A, R515B)  
 HC (R290, R600, R600A, R1270)



### Product details

Attacchi SAE Flare 3/4"

Attacchi ODS Ø [in.] -

ODS Ø [mm] -

Kv [m<sup>3</sup>/h] 5

Pressione differenziale (2) [bar] 0,04

PS [bar] 50

MWP [psi] (1) 600

TS [°C] min. -40

TS [°C] max. +150

## Notes

(1): in conformità a omologazione UL

(2): minima pressione a cui la valvola è completamente aperta