

Product Code

3113W/4

Check Valve

1/2" Flare


PS = 50 bar - 600 PSI



Product use

Accessories for use with the following ASHRAE 34:2019 refrigerants, Class A1, A2L, or A3:

- HFC (R134A, R32, R404A, R407C, R410A, R507)
- HFO (R1234YF, R1234ZE)
- HFO + HFC (R448A, R449A, R450A, R452A, R452B, R454A, R454B, R454C, R455A, R513A, R515A, R515B)
- HC (R290, R600, R600A, R1270)



Product details

Attacchi SAE Flare 1/2"

Attacchi ODS Ø [in.] -

ODS Ø [mm] -

Kv [m³/h] 1,8

Pressione differenziale (2) [bar] 0,3

PS [bar] 50

MWP [psi] (1) 600

TS [°C] min. -40

TS [°C] max. +150

Notes

(1): in conformità a omologazione UL

(2): minima pressione a cui la valvola è completamente aperta