

Product Code

3112W/6

Check Valve


3/4" Flare

PS = 50 bar - 600 PSI



Product use

Accessories for use with the following ASHRAE 34:2019 refrigerants, Class A1, A2L, or A3:
 HFC (R134A, R32, R404A, R407C, R410A, R507)
 HFO (R1234YF, R1234ZE)
 HFO + HFC (R448A, R449A, R450A, R452A, R452B, R454A, R454B, R454C, R455A, R513A, R515A, R515B)
 HC (R290, R600, R600A, R1270)



Product details

Dibujo img(3112W_2.jpg)

N° catálogo 3112W/6

Conexiones SAE Flare 3/4"

Conexiones ODS Ø [in.] -

ODS Ø [mm] -

Kv [m³/h] 5

Presión diferencial (2) [bar] 0,04

PS [bar] 50

MWP [psi] (1) 600

| | |
|----------------------|------|
| TS [°C] min. | -40 |
| TS [°C] max. | +150 |
| Paquete de n° piezas | 16 |

Notes

(1): en conformidad con la homologación UL

(2): mínima presión con la cual la válvula está totalmente abierta