

Product Code

DF341/4

Solid Core Filter Drier

1/2" Flare

PS = 50 bar - 680 PSI



Product use

Accessories for use with the following ASHRAE 34:2019 refrigerants, Class A1, A2L, or A3:

HCFC (R22)

HFC (R134a, R404A, R407C, R410A, R507)

HFO (R1234ze)

HFO + HFC (R448A, R449A, R450A, R452A, R513A, R515A, R515B)

HC (R290, R600, R600a, R1270)

Product details

International code 414

Connections SAE Flare 1/2"

Nominal volume [cm³] 670

PS [bar] 50

MWP [psi] (1) 680

TS [°C] min. -40

TS [°C] max. +80

Package pcs 6

Notes

(1): according to UL approval