



## Product Code

# 3145NW/17

Check Valve

2.1/8" ODS

PS = 50 bar - 650 PSI

**P**  **LYHEDRA**

### Product use

Accessories for use with the following ASHRAE 34:2019 refrigerants, Class A1, A2L, or A3:  
HFC (R134A, R32, R404A, R407C, R410A, R507)  
HFO (R1234YF, R1234ZE)  
HFO + HFC (R448A, R449A, R450A, R452A, R452B, R454A, R454B, R454C, R455A, R513A, R515A, R515B)  
HC (R290, R600, R600A, R1270)

### Product details

Raccords ODS Ø [in.] 2.1/8"

Raccords ODS Ø [mm] 54

Kv [m<sup>3</sup>/h] 39

Pression différentielle (2) [bar] 0,3

PS [bar] 50

MWP [psi] (1) 650

TS [°C] Min -40

TS [°C] Max +150

Emballage 1

## Notes

(1): conformément à homologation UL

(2): pression minimum à laquelle le clapet est complètement ouvert