

Product Code

**4375N/9S**

Solid Core Filter Drier

1.1/8" ODS

PS = 50 bar - (2) PSI



### Product use

Accessories for use with the following ASHRAE 34:2019 refrigerants, Class A1, A2L, or A3:

HFC (R134A, R32, R404A, R407C, R410A, R507)

HFO (R1234YF, R1234ZE)

HFO + HFC (R448A, R449A, R450A, R452A, R452B, R454A, R454B, R454C, R455A, R513A, R515A, R515B)

HC (R290, R600, R600A, R1270)

### Product details

Internationaler code 759S

Anschlüsse ODS Ø [in.] 1.1/8"

Anschlüsse ODS Ø [mm] -

Nominaler rauminhalt [cm<sup>3</sup>] 1340

PS[bar] 50

MWP [psi] (1) (2)

TS[°C] Min -40

TS[°C] Max +80

Verpackung 1

## Notes

(1): Übereinstimmung zur UL-Zulassung

(2): Ohne UL-Zertifizierung