



## Product Code

# 3144NW/17

Check Valve

2.1/8" ODS

PS = 50 bar - 650 PSI

**P**  **LYHEDRA**

### Product use

Accessories for use with the following ASHRAE 34:2019 refrigerants, Class A1, A2L, or A3:

HFC (R134A, R32, R404A, R407C, R410A, R507)

HFO (R1234YF, R1234ZE)

HFO + HFC (R448A, R449A, R450A, R452A, R452B, R454A, R454B, R454C, R455A, R513A, R515A, R515B)

HC (R290, R600, R600A, R1270)

### Product details

**Anschlüsse ODS Ø [in.]** 2.1/8"

**Anschlüsse ODS Ø [mm]** 54

**Kv [m<sup>3</sup>/h]** 39

**Differenzial Druck (2) [bar]** 0,04

**PS [bar]** 50

**MWP [psi] (1)** 650

**TS [°C] Min** -40

**TS [°C] Max** +150

**Verpackung** 1

## Notes

(1): Übereinstimmung zur UL-Zulassung

(2): minimaler Druck, bei dem das Ventil vollständig geöffnet ist